



## Plan Review Routing Comments

### Project Information

Project: Fire Dept. Bldg.  
Revision: Original  
Type: Project Public  
Logos ID: PROJ-PUBLIC – 2016-00000002

### Comments

- Water Dept.: Randy Harvey: Approved with Comments.
  1. See Water Dept. to discuss water tap and metering details.
  2. We highly recommend that 200 PSI CTS (Copper Tube Size) plastic pipe is used.
- Bldg. Dept.: Dave Fuller: Approved.
- WPC Dept.: David Lochner: Approved with Comments.
  1. Sanitary connection must be a cut in wye fitting.
- Fire Dept.: Ryan Shambaugh: Approved.
- Engineering Dept.: Steve Klein: Approved.