



## Plan Review & Routing Comment Form

### Project Information

Project: Auburn Community Commons - Development Plan  
Revision: Preliminary  
Type: Development Plan  
Logos ID: PROJ-PUBLIC - 2020-00000002  
Due Date: **Jan 15, 2020**

### Reviewer Information

Name: Eric Ditmars  
Dept.: Auburn Parks and Recreation  
Phone: 260-925-2997

### Comments *(add more numbers and pages, if necessary)*

1. The natural gas meters may need a separation barrier to reduce the possibility of intentional or unintentional damage.
2. I do agree with BPD comments, the chase way is very small to serve as a functioning work area once you add all of the exposed piping and necessary supports for wall mounted fixtures.

### Recommended Action

           Approve  
  X   Approve with Comments  
           Revise and Resubmit  
           Other:

*BPD Use Only*

Rec'd By: \_\_\_\_\_  
Date: \_\_\_\_\_