



Plan Review & Routing Comment Form

Project Information

Project: Fire Dept. Bldg.
Revision: Original
Type: Project Public
Logos ID: PROJ-PUBLIC – 2016-00000002
Due Date: **November 9, 2016**

Reviewer Information

Name: David Lochner
Dept.: WPC
Phone: 260-925-1714

Comments *(add more numbers and pages, if necessary)*

1. Sanitary connection must be a cut in wye fitting.
- 2.

Recommended Action

Approve
 Approve with Comments
 Revise and Resubmit
 Other:

<i>BPD Use Only</i> Rec'd By: MAL Date: 11.04.2016
--