### INDIANA DEPARTMENT OF HOMELAND SECURITY



# WRITTEN COMMENT ON APPLICATION FOR VARIANCE

Variance Number Commenting On:
COMMENTOR INFORMATION
Name of Commentor: Kellie C. Knauer
Mailing Address: 210 S. Cedar Street, 2nd Floor/ P.O. Box 506
Email Address: kcknauer@ci.auburn.in.us
Representing: City of Aubum, Building, Planning & Development
Official Title/Position (if applicable): Administrator- Building Commissioner
COMMENT
Position: I have no objection to this variance.
Reason for Position:

The installation of the proposed fire suppression system will provide adequate protection for the second floor tenant space equal to or greater than the two (2) hour horizontal assembly.

### **Recommended Conditions If Approved:**

Sprinkler system design density be increased to .2/1500 Group 2 Hazard as proposed.

Comment on Undue Hardship Claimed:

## The stated hardship is reasonable.

Comment on Impact to Public Health, Safety, or Welfare:

### The variance is not adverse to the occupants.

#### **ADDITIONAL INFORMATION**

**Attachments:** 

By submitting this comment, I certify the information contained in this document is true, accurate, and complete.