



Plan Review & Routing Comment Form

Project Information

Project: Fire Dept. Bldg.
Revision: Original
Type: Project Public
Logos ID: PROJ-PUBLIC – 2016-00000002
Due Date: **November 9, 2016**

Reviewer Information

Name: Randy Harvey
Dept.: Water
Phone: 260-925-5711

Comments *(add more numbers and pages, if necessary)*

1. See Water Dept to discuss water tap and metering details.
2. We highly recommend that 200 p.s.i. CTS (Copper Tube Size) plastic pipe is used.

Recommended Action

 Approve
 X Approve with Comments
 Revise and Resubmit
 Other:

BPD Use Only
Rec'd By: MAL
Date: 11.02.2016