



# Plan Review & Routing Comment Form

## Project Information

Project: Rieke Park Entrance  
 Revision: Original  
 Type: Project Public – Improvement Location Permit & Sign Permit  
 Logos ID: PROJ-PUBLIC - 2017-00000003  
 Due Date: **November 15, 2017**

## Reviewer Information

Name: Randy Harvey  
 Dept.: Water  
 Phone: 260-925-5711

## Comments *(add more numbers and pages, if necessary)*

1. Take caution if excavating 4-5' deep. There is a 16" water main in the area on that side of the road.
- 2.

## Recommended Action

- Approve  
 Approve with Comments  
 Revise and Resubmit  
 Other:

<p><i>BPD Use Only</i>          Rec'd By: MAL          Date: 11.06.2017</p>
---